

year	organisatic	scheme id	scheme	scheme lor	scheme ty	kpi code	swim code	indicator	ti value	units	comments
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.4a	AS1	Number w		1 Count	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.1	AS2	Length wat		132.5 km	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.4b	AS47	Capacity of		4 ML/day	limited by capacity of inlet pipes and raw water pumping system
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.7	AS48	Total potal		11 ML	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.23	AS56	Volume w		131.6 ML	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG4.5	AS8	Water mai		1.5 per 100 km water main	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG4.12	CS10	Water serv		0 per 1000 connections	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG4.14	CS12	Water and		0 per 1000 connections	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG4.11	CS13	Water and		0 per 1000 connections	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG4.7	CS17	Average fr		2.3 per 1000 connections	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.13	CS2	Connected		0.735 000s	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.14	CS3	Connected		0.135 000s	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG4.8a	CS66	Percent CS		100 %	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG4.10	CS9	Water qual		0 per 1000 connections	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG4.1(valu	PR3	Fixed char		1056 \$/annum	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG4.1(text	PR5	Fixed char		Per entitle	Text
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.8	WA1	Volume w		920 ML	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.9a	WA2	Volume w		51.5 ML	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.5	WA201	Maximum		3.8 ML/day	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.21	WA223	Volume all		0 ML	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.22	WA224	Volume all		0 ML	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.6a	WA225	Volume po		949.3 ML	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.17a	WA32	Volume po		465.8 ML	worked out on percentages of previous year. Billing report not completed at the time of compiling this report. Total metered consumption of 784,256kL + raw water
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.18a	WA34	Volume po		318.4 ML	worked out on percentages of previous year. Billing report not completed at the time of compiling this report
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.10	WA61	Volume w		1 ML	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG1.12	WA7	Volume w		972.5 ML	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG2.10a	WS11	Water rest		365 days	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG2.10b	WS12	Water rest		0 days	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG2.10c	WS13	Water rest		0 days	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG2.10d	WS14	Water rest		0 days	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG2.10e	WS15	Water rest NR		days	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG2.10f	WS16	Water rest NR		days	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG2.11a	WS17	Has asset r	yes	yes/no	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG2.11b	WS18	Has drougl	yes	yes/no	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG2.11c	WS19	Has water	no	yes/no	no
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG2.11d	WS20	Has assess	yes	yes/no	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG2.11e	WS21	Has the tin	yes	yes/no	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG2.12	WS22	Months w		4 1,2,3,4,5,6	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG2.13	WS23	Confidence	high	high,fair,unsure,low,very low	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG2.14	WS24	Confidence	high	high,fair,unsure,low,very low	
2021	Carpentari	1162	Normantor	Normantor	Potable w	QG2.3	WS3	Available c	yes	yes/no	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG1.1	AS2	Length wat		30 km	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG4.5	AS8	Water mai		13.3 per 100 km water main	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG4.12	CS10	Water serv		0 per 1000 connections	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG4.14	CS12	Water and		0 per 1000 connections	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG4.11	CS13	Water and		0 per 1000 connections	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG1.13	CS2	Connected		0.01 000s	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG1.14	CS3	Connected		0.004 000s	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG4.8a	CS66	Percent CS		100 %	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG4.10	CS9	Water qual		0 per 1000 connections	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG4.1(valu	PR3	Fixed char	NR	\$/annum	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG4.1(text	PR5	Fixed char	Per kL	Text	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG1.8	WA1	Volume w		18 ML	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG1.9a	WA2	Volume w		0 ML	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG1.5	WA201	Maximum		0.1 ML/day	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG1.21	WA223	Volume all		0 ML	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG1.22	WA224	Volume all		0 ML	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG1.10	WA61	Volume w		0 ML	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG1.12	WA7	Volume w		18 ML	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG1.17b	WA91	Volume ra		15.3 ML	
2021	Carpentari	12877	Normantor	Normantor	Raw-Partia	QG1.18b	WA92	Volume ra		0.3 ML	

2021	Carpentari	12877	Normantor Normantor Raw-Partia QG2.10a	WS11	Water rest	365 days
2021	Carpentari	12877	Normantor Normantor Raw-Partia QG2.10b	WS12	Water rest	0 days
2021	Carpentari	12877	Normantor Normantor Raw-Partia QG2.10c	WS13	Water rest	0 days
2021	Carpentari	12877	Normantor Normantor Raw-Partia QG2.10d	WS14	Water rest	0 days
2021	Carpentari	12877	Normantor Normantor Raw-Partia QG2.10e	WS15	Water rest NR	days
2021	Carpentari	12877	Normantor Normantor Raw-Partia QG2.10f	WS16	Water rest NR	days
2021	Carpentari	12877	Normantor Normantor Raw-Partia QG2.11a	WS17	Has asset r	yes/no
2021	Carpentari	12877	Normantor Normantor Raw-Partia QG2.11b	WS18	Has drought	yes/no
2021	Carpentari	12877	Normantor Normantor Raw-Partia QG2.11c	WS19	Has water	no yes/no no
2021	Carpentari	12877	Normantor Normantor Raw-Partia QG2.11d	WS20	Has assess	yes/no
2021	Carpentari	12877	Normantor Normantor Raw-Partia QG2.11e	WS21	Has the tin	yes/no
2021	Carpentari	12877	Normantor Normantor Raw-Partia QG2.12	WS22	Months w	4 1,2,3,4,5,6
2021	Carpentari	12877	Normantia Normantor Raw-Partia QG2.13	WS23	Confidence high	high,fair,unsure,low,very low
2021	Carpentari	12877	Normantor Normantor Raw-Partia QG2.14	WS24	Confidence high	high,fair,unsure,low,very low
2021	Carpentari	12877	Normantor Normantor Raw-Partia QG2.3	WS3	Available c	no yes/no
2021	Carpentari	17734	Karumba R Karumba N Recycled w QG1.1	AS2	Length wal	1 km
2021	Carpentari	17734	Karumba R Karumba N Recycled w QG4.5	AS8	Water mai	200 per 100 km water main
2021	Carpentari	17734	Karumba R Karumba N Recycled w QG4.12	CS10	Water serv	0 per 1000 connections
2021	Carpentari	17734	Karumba R Karumba N Recycled w QG4.14	CS12	Water and	0 per 1000 connections
2021	Carpentari	17734	Karumba R Karumba N Recycled w QG4.11	CS13	Water and	0 per 1000 connections
2021	Carpentari	17734	Karumba R Karumba N Recycled w QG1.13	CS2	Connected	0 000s
2021	Carpentari	17734	Karumba R Karumba N Recycled w QG1.14	CS3	Connected	0.001 000s
2021	Carpentari	17734	Karumba R Karumba N Recycled w QG4.10	CS9	Water qual	0 per 1000 connections
2021	Carpentari	17734	Karumba R Karumba N Recycled w QG4.1(val PR3	PR3	Fixed char	0 \$/annum
2021	Carpentari	17734	Karumba R Karumba N Recycled w QG4.1(text PR5	PR5	Fixed char	no charge Text
2021	Carpentari	17734	Karumba R Karumba N Recycled w QG1.21	WA223	Volume all	0 ML
2021	Carpentari	17734	Karumba R Karumba N Recycled w QG1.22	WA224	Volume all	0 ML
2021	Carpentari	17734	Karumba R Karumba N Recycled w QG1.11	WA26	Volume rec	54 ML
2021	Carpentari	17734	Karumba R Karumba N Recycled w QG1.12	WA7	Volume w	54 ML
2021	Carpentari	11267	Karumba S Karumba L Sewerage : QG4.6	AS39	Sewerage :	0 per 100 km sewer mains
2021	Carpentari	11267	Karumba S Karumba L Sewerage : QG1.3	AS4	Number se	1 Count
2021	Carpentari	11267	Karumba S Karumba L Sewerage : QG1.2	AS5	Length sev	17 km
2021	Carpentari	11267	Karumba S Karumba L Sewerage : QG4.13	CS11	Sewerage :	0 per 1000 connections
2021	Carpentari	11267	Karumba S Karumba L Sewerage : QG4.14	CS12	Water and	0 per 1000 connections
2021	Carpentari	11267	Karumba S Karumba L Sewerage : QG4.11	CS13	Water and	0 per 1000 connections
2021	Carpentari	11267	Karumba S Karumba L Sewerage : QG1.15	CS6	Connected	0.296 000s
2021	Carpentari	11267	Karumba S Karumba L Sewerage : QG4.9a	CS65	Percent CS	100 %
2021	Carpentari	11267	Karumba S Karumba L Sewerage : QG1.16	CS7	Connected	0.051 000s
2021	Carpentari	11267	Karumba S Karumba L Sewerage : QG4.2(val PR31	PR31	Fixed char	1176.3 \$/annum
2021	Carpentari	11267	Karumba S Karumba L Sewerage : QG4.2(text PR40	PR40	Fixed char	Per proper Text
2021	Carpentari	991	Normantor Normantor Sewerage : QG4.6	AS39	Sewerage :	8.8 per 100 km sewer mains
2021	Carpentari	991	Normantor Normantor Sewerage : QG1.3	AS4	Number se	1 Count
2021	Carpentari	991	Normantor Normantor Sewerage : QG1.2	AS5	Length sev	22.7 km
2021	Carpentari	991	Normantor Normantor Sewerage : QG4.13	CS11	Sewerage :	0 per 1000 connections
2021	Carpentari	991	Normantor Normantor Sewerage : QG4.14	CS12	Water and	0 per 1000 connections
2021	Carpentari	991	Normantor Normantor Sewerage : QG4.11	CS13	Water and	0 per 1000 connections
2021	Carpentari	991	Normantor Normantor Sewerage : QG1.15	CS6	Connected	0.417 000s
2021	Carpentari	991	Normantor Normantor Sewerage : QG4.9a	CS65	Percent CS	100 %
2021	Carpentari	991	Normantor Normantor Sewerage : QG1.16	CS7	Connected	0.058 000s
2021	Carpentari	991	Normantor Normantor Sewerage : QG4.2(val PR31	PR31	Fixed char	824.8 \$/annum
2021	Carpentari	991	Normantor Normantor Sewerage : QG4.2(text PR40	PR40	Fixed char	Per proper Text
2021	Carpentari	1328	Carpentari: Carpentari: WSP QG1.4a	AS1	Number w	1 Count
2021	Carpentari	1328	Carpentari: Carpentari: WSP QG1.1	AS2	Length wal	163.5 km
2021	Carpentari	1328	Carpentari: Carpentari: WSP QG4.6	AS39	Sewerage :	5 per 100 km sewer mains
2021	Carpentari	1328	Carpentari: Carpentari: WSP QG1.3	AS4	Number se	2 Count
2021	Carpentari	1328	Carpentari: Carpentari: WSP QG1.4b	AS47	Capacity of	4 ML/day
2021	Carpentari	1328	Carpentari: Carpentari: WSP QG1.7	AS48	Total pota	11 ML
2021	Carpentari	1328	Carpentari: Carpentari: WSP QG1.2	AS5	Length sev	39.7 km
2021	Carpentari	1328	Carpentari: Carpentari: WSP QG1.23	AS56	Volume w	131.6 ML
2021	Carpentari	1328	Carpentari: Carpentari: WSP QG4.5	AS8	Water mai	4.9 per 100 km water main
2021	Carpentari	1328	Carpentari: Carpentari: WSP QG4.12	CS10	Water serv	0 per 1000 connections
2021	Carpentari	1328	Carpentari: Carpentari: WSP QG4.13	CS11	Sewerage :	0 per 1000 connections

2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG4.14	CS12	Water and	0 per 1000 connections	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG4.11	CS13	Water and	0 per 1000 connections	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG4.7	CS17	Average fr	2.3 per 1000 connections	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.13	CS2	Connected	0.745 000s	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.14	CS3	Connected	0.139 000s	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.15	CS6	Connected	0.713 000s	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG4.9a	CS65	Percent CS	100 %	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG4.8a	CS66	Percent CS	100 %	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.16	CS7	Connected	0.109 000s	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG4.10	CS9	Water qual	0 per 1000 connections	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.9	FN1	Revenue: a	1922.182 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.6	FN10	Nominal w	16420.5 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.11	FN11	Costs: opei	1066.12 \$/connection	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.12	FN12	Costs: opei	621.59 \$/connection	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.1	FN14	Capital exp	1409 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.2	FN15	Capital exp	485.502 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.10	FN2	Revenue: a	1600.501 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.3	FN26	Capital wo	915.729 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.4	FN27	Capital wo	38.891 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.11a	FN32	Costs: opei	942.449 \$,000	taken from Council's accounting system (Synergy)
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.12a	FN33	Costs: opei	510.951 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.21	FN49	Costs: any	0 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.22	FN50	Costs: any	0 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.7	FN74	Current re	75576.66 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.8	FN75	Current re	25332.3 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.13	FN76	Costs: mair	291.522 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.14	FN77	Costs: mair	359.839 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.15	FN78	Current co	1136.082 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.16	FN79	Current co	451.703 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.17	FN80	Previous 5	764.768 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.18	FN81	Previous 5	181.505 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.19	FN82	Forecast 5	1000 \$,000	forecasts offered by finance
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.20	FN83	Forecast 5	300 \$,000	forecasts offered by finance
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG3.5	FN9	Nominal w	44645.13 \$,000	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG4.1(val	PR3	Fixed char	1056 \$/annum	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG4.2(val	PR31	Fixed char	824.8 \$/annum	Normanton has the most sewer connections
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG4.2(text	PR40	Fixed char	Per proper Text	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG4.3	PR47	Annual bill	1880.8 \$	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG4.4	PR48	Typical resi	2024.48 \$	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG4.1(text	PR5	Fixed char	Per entitle	Text
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.8	WA1	Volume wa	938 ML	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.9a	WA2	Volume wa	51.5 ML	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.5	WA201	Maximum	3.9 ML/day	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.21	WA223	Volume all	0 ML	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.22	WA224	Volume all	0 ML	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.6a	WA225	Volume po	949.3 ML	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.11	WA26	Volume rec	54 ML	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.17a	WA32	Volume po	465.8 ML	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.18a	WA34	Volume po	318.4 ML	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.10	WA61	Volume wa	1 ML	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.12	WA7	Volume wa	1044.5 ML	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.17b	WA91	Volume ra	15.3 ML	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.18b	WA92	Volume ra	0.3 ML	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG1.20	WF1	Total full-ti	6 FTEs	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG2.10a	WS11	Water rest	365 days	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG2.10b	WS12	Water rest	0 days	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG2.10c	WS13	Water rest	0 days	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG2.10d	WS14	Water rest	0 days	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG2.10e	WS15	Water rest NR	days	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG2.10f	WS16	Water rest NR	days	
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG2.11a	WS17	Has asset r	yes	yes/no
2021	Carpentari	1328	Carpentari: Carpentari: WSP	QG2.11b	WS18	Has droug	yes	yes/no

2021 Carpentari:	1328 Carpentari: Carpentari: WSP	QG2.11c	WS19	Has water	no	yes/no	no population increase expected in foreseeable future
2021 Carpentari:	1328 Carpentari: Carpentari: WSP	QG2.11d	WS20	Has assess	yes	yes/no	
2021 Carpentari:	1328 Carpentari: Carpentari: WSP	QG2.11e	WS21	Has the tin	yes	yes/no	
2021 Carpentari:	1328 Carpentari: Carpentari: WSP	QG2.12	WS22	Months w	4	1,2,3,4,5,6	
2021 Carpentari:	1328 Carpentari: Carpentari: WSP	QG2.13	WS23	Confidence	high	high,fair,unsure,low,very low	
2021 Carpentari:	1328 Carpentari: Carpentari: WSP	QG2.14	WS24	Confidence	high	high,fair,unsure,low,very low	
2021 Carpentari:	1328 Carpentari: Carpentari: WSP	QG2.3	WS3	Available c	yes	yes/no	